

DIVISION LEVEL WATER TESTING LABORATORY
MUNICIPAL CORPORATION, ABOHAR
ANALYSIS REPORT OF WATER SAMPLE

Particulars of sample

Dated: 8/June/2021

1.	Name/Address	Brahmrishi School, Abohar
2.	Sample collected by :	Punjab Water Supply & Sewerage Board Abohar
3.	Method of sampling	IS-3025 (Part I)
4.	Date & time of collection	8/June/2021
5.	Name & Designation of person collecting sample	Kulwinder/singh


TEST PARAMETERS

PHYSICAL & CHEMICAL

Sr. No.	Parameters	BIS10500 (Acceptable limit)	Permissible limit in absence of alternative source	Result
1	Turbidity (JTU)	0	<5	1.27
2	P.H.	6.5	8.5	7.2
3	Total Dissolved Solids(MG/L)	60	1500	391
4	Free Residual Chlorine (As CL) P.P.M	0.1	2	—
5	Taste & Odours (Qualitative)	Agreeable	Non-Agreeable	Agreeable
6	Ammonia	0.5	No relaxation	0.0244
7	Total Hardness [MG/L]	0	600	250
8	Alkanity	0	600	225
9	Chlorides[MG/L]	0	900	90
10	Fluorides[MG/L]	0	1.5	1.2
11	Phosphate[MG/L]	0	3	0.0948
12	Nitrate[MG/L]	0	40	10
13	Nitrite[MG/L]	0	3	0.0343
14	Iron[MG/L]	0.3	0.3	0.05

Remarks : (In view of the above analysis)

1. The water is potable/non potable as tested result.
2. The analyse parameters are More/Less than acceptable, but More/Less than the cause of rejection limits.


 Technical Manager,
 Municipal Corporation, Abohar.
 Division Level Water Testing,
 Abohar Laboratory.

Shreyas

Principal
 Brahmrishi Mission Sen. Sec. School
 ABOHAR


 Managing Director
 Brahmrishi Mission Sen. Sec. School
 ABOHAR

ਦਫਤਰ ਨਗਰ ਨਿਗਮ ਅਬੋਹਰ ਜਿਲ੍ਹਾ ਫਾਜ਼ਿਲਕਾ

ਵੱਲ,

ਪਿੰਸੀਪਲ,

ਬ੍ਰਹਮਰਿਸ਼ੀ ਸੀਨੀਅਰ ਸੈਕੰਡਰੀ ਸਕੂਲ,

ਹਨੂੰਮਾਨਗੜ੍ਹ ਰੋਡ, ਅਬੋਹਰ।

ਨੰਬਰ 1234.....

ਮਿਤੀ 28/5/22

ਵਿਸ਼ਾ :- ਰਿਕ੍ਰੂਟਮੈਂਟ ਫਾਰਮ ਇੰਸਟ੍ਰਿਕਟਿੰਗ ਆਫ ਸੈਨੇਟਰੀ ਸਰਟੀਫਿਕੇਟ।

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਸਬੰਧੀ ਬ੍ਰਹਮਰਿਸ਼ੀ ਸੀਨੀਅਰ ਸੈਕੰਡਰੀ ਸਕੂਲ ਹਨੂੰਮਾਨਗੜ੍ਹ ਰੋਡ
ਅਬੋਹਰ ਦੀ ਸਫਾਈ ਦਾ ਮੁਆਇਨਾ ਕੀਤਾ ਗਿਆ ਜੋ ਕਿ ਸੰਤੁਸ਼ਟੀਜਨਕ ਹੈ।

Shruti
ਸੈਨੇਟਰੀ ਇੰਸਪੈਕਟਰ,
ਨਗਰ ਨਿਗਮ, ਅਬੋਹਰ।

Munish M

Shreya
01/10/22

Principal
Brahmrishi Mission Sen. Sec. School
ABOHAR

Shreya
Managing Director
Brahmrishi Mission Sen. Sec. School
ABOHAR
11/10/22