

ਦਫਤਰ ਨਗਰ ਨਿਗਮ ਅਬੋਹਰ ਜਿਲ੍ਹਾ ਫਾਜ਼ਿਲਕਾ

ਵੱਲੋਂ

ਪ੍ਰਿੰਸੀਪਲ,  
ਬ੍ਰਹਮਰਿਸ਼ੀ ਮਿਸ਼ਨ ਸਕੂਲ,  
ਹਨੂੰਮਾਨਗੜ੍ਹ ਰੋਡ, ਅਬੋਹਰ।

ਨੰਬਰ.....1360.....

ਮਿਤੀ....14/5/26...

ਵਿਸ਼ਾ:- ਰਿਕੂਐਸਟ ਫਾਰਮ ਇੰਸੂਟਿੰਗ ਆਫ ਸੈਨੇਟਰੀ ਸਰਟੀਫਿਕੇਟ

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਸਬੰਧੀ ਬ੍ਰਹਮਰਿਸ਼ੀ ਮਿਸ਼ਨ ਸਕੂਲ ਹਨੂੰਮਾਨਗੜ੍ਹ ਰੋਡ ਅਬੋਹਰ ਦੀ ਸਫਾਈ ਦਾ ਮੁਆਇਨਾ ਕੀਤਾ ਗਿਆ ਜੋ ਕਿ ਸੰਤੁਸ਼ਟੀਜਨਕ ਹੈ।

*S. S. G. G. G.*  
ਈ. ਸੈਨੇਟਰੀ ਇੰਸਪੈਕਟਰ  
14/05/26  
ਨਗਰ ਨਿਗਮ, ਅਬੋਹਰ।

*Shreyas*  
29/05/26  
Principal  
Brahmrishi Mission School  
ABOHAR

*Brahmrishi*  
29/05/26  
Manager  
Brahmrishi Mission School  
ABOHAR

**SUB-DIVISION LEVEL WATER TESTING LABORATORY  
MUNICIPAL CORPORATION, ABOHAR  
ANALYSIS REPORT OF WATER SAMPLE**

Sr.No. MC-228 B

Received Dispatch No. 16.B.M.S/2627

Particular sample:

DATE: 29/04/2026

1.	Name/Address	<u>Brahmrishi Mission School, Abohar / Sample I</u>
2.	Block/District	<u>Abohar / Fazilka</u>
3.	Sealed/Unsealed	<u>Unsealed</u>
4.	Date & Time of collection	<u>26/04/2026</u>

**TEST RESULTS**

**PHYSICAL & CHEMICAL TEST REPORT**


Sr. No.	Parameters	Test Method IS	Requirement (Acceptable Limits)	Max. Permissible limit absence of alternative source	Result Analysis
1	Order & Taste	IS 3025, Part 4			
2	Turbidity (JTU)	IS3025 Part 10	1	5	<u>Agreeable</u> <u>0.0</u>
3	Total Dissolved Solids (MG/L)	IS3025 Part 16	500mg/l	2000mg/l	<u>121</u>
4	P.H. Value	IS3025 Part 11	6.5-8.5	No Relaxation	<u>6.7</u>
5	Free Residual Chlorine (As CL) P.P.M	IS3025 Part 26	0.2	1	<u>—</u>
6	Electrical Conductivity	IS3025	1	700	<u>224</u>
7	Alkalinity (as Calcium Carbonate) (MG/L)	IS3025 Part 23	200mg/l	600mg/l	<u>75</u>
8	Total Hardness CaCO <sub>3</sub> (MG/L)	IS3025 Part 21	200mg/l	600mg/l	<u>50</u>
9	Chlorides (as CL) (MG/L)	IS3025 Part 32	250mg/l	1000mg/l	<u>30</u>
10	Fluorides (as F) (MG/L)	IS3025 Part 60	1 mg/l	1.5 mg/l	<u>0.2</u>
11	Nitrite (MG/L)	IS3025	3 mg/l	No Relaxation	<u>N.D.</u>
12	Nitrate (as NO <sub>3</sub> ) (MG/L)	IS3025 Part 34	45 mg/l	40 mg/l	<u>N.D.</u>
13	Iron (MG/L)	IS3025 Part 53	0.3 (MG/L)	0.3 (MG/L)	<u>N.D.</u>
14	Phosphate (MG/L)	IS3025	3 mg/l	No Relaxation	<u>N.D.</u>
15	Dissolve Oxygen (MG/L)	IS3025	5 mg/l	9 mg/l	<u>7.5</u>
16	Ammonia (MG/L)	IS3025 Part 34			<u>N.D.</u>


Remarks: (In view of the above analysis)

1. The water is **potable/non-potable** as tested result.
2. The following parameters are more than acceptable but less than the cause of **rejection limits**.
3. N.D. Stand For Not Detected.

NOTE:- This result relates to the sample provided to us and the laboratory is not responsible for drawing /collecting of samples. The contents of this report are meant for your guidance and should not be used for advertisement, Evidence and Litigation. These test documents shall not be reproduced without the permission of the Municipal Commissioner.

  
 Municipal Corporation, Abohar  
 Sub-Division Quality Water Testing,  
 Abohar Laboratory.

  
 Principal  
 Brahmishi Mission School  
 ABOHAR

  
 Manager  
 Brahmishi Mission School  
 ABOHAR